

**STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC POOL AND BATHING PLACE  
INSPECTION REPORT**



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 36-60-00541  
Name of Facility: Spring Woods Mobile Home Pool  
Address: 2375 Zoysia Lane  
City, Zip: North Fort Myers 33917

**Correct By: Next Inspection  
Re-Inspection Date: None**

Type: Public Pool > 25000 Gallons  
Owner: Spring Woods Mobile Home Subdivision Homeowners Association, Inc.  
Person In Charge: Spring Woods Mobile Home Subdivision Homeowners Association, Inc.  
Phone: 239-543-8172  
PIC Email: springwoodshoa2375@gmail.com  
Pool Operator: Gully Pool Service & Supply\* Phone: (239) 334-8501

**Inspection Information**

Purpose: Reinspection  
Inspection Date: 5/21/2026

Begin Time: 10:50 AM  
End Time: 11:30 AM

**Additional Information**

22. Free Chlorine .....	2.5	VOLUME .....	27825
23. pH .....	7.6	POOL LOAD .....	20
24. Chlor. Stabilizer .....	30	FLOW RATE .....	100
33. Flowmeter .....	85	NIGHT SWIM .....	No
34. Thermometer .....	87	FILTER TYPE .....	DEV

*Items checked are not in compliance with Chapter 386 or 514, Florida Statutes, or Chapter 64E-9 or 64E-10, Florida Administrative Code. These violations must be corrected by the date indicated to avoid closure, administrative fines, or other legal actions. Florida Building Code (FBC) violations are reported to the local building official, and depending upon risk severity, the Department of Health may close the pool or rescind the operating permit.*

**Violation Markings**

<b>POOL AREA</b> 1. Water Clarity/Algae Control 2. Deck/Walkways 3. Tile/Pool Finish 4. Depth Markers-FBC 5. Handrail/Ladder-FBC 6. Step Markings-FBC 7. Suction Outlets-514.0315(1) 8. Gutter Grates/Skimmer-FBC X 9. Lighting 10. No Dive Markings-FBC 11. Diving Board-FBC 12. Pool Cover 13. Pool Side Shower-FBC <b>POOL SAFETY</b> 14. Life Hook(s) w/Pole 15. Life Ring(s) w/Rope 16. Safety Line	17. Rules Posted 18. Certification <b>SANITARY FACILITIES</b> 19. Supplies 64E-10, FAC 20. Clean 64E-10, FAC <b>WATER QUALITY</b> 21. Approved Test Kit 22. Free Chlor./Brom. 23. pH 24. Chlor. Stabilizer 25. Spa Requirements-ORP <b>EQUIPMENT ROOM</b> 26. Wading Pool-Quick Dump 27. Water Level/Control X 28. Disinfection Feeder/Generator 29. pH Feeder 30. Chem. Container Label-FBC 31. Filter / Pump	32. Vacuum Cleaner-FBC 33. Flowmeter 34. Thermometer 35. Pressure/Vacuum Gauge 36. Equip. Room 37. Cross Connection 38. Gas Chlorine Eq.-FBC 39. Waste Water - FBC 40. D.E. Separator-FBC 41. Other Equipment 42. Equip. Change-FBC 43. Approved Chemicals 44. Maintenance Log 45. Inspection Posted 46. Safety-514.0315(2) 47. Fences/Gates- FBC 48. Other 49. Other
---	---	--

*NOTE: It is unlawful to modify a public pool or its equipment without prior approval from the local building department and submitting an application to DOH.*

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC POOL AND BATHING PLACE  
INSPECTION REPORT



2 of 2

**General Comments**

-Inspection scheduled for 5/22/2026 and rescheduled for 5/21/2026 by Homeowners Association due to completion of work.

Email Address(es): ohlstein@aol.com;  
springwoodsHOA2375@gmail.com;

DOH Web Page For Pools: <http://www.floridahealth.gov/environmental-health/swimming-pools/index.html>

**Violations Comments**

Violation #9. Lighting

-Underwater light not flush with wall

CODE REFERENCE: Lighting Pool/Area. 64E-9.008(7). Underwater and outside lighting shall be provided for night swimming in accordance with the FBC, or the pool must be closed at night.

Violation #28. Disinfection Feeder/Generator

-Erosion feeder missing rate of flow indicator

CODE REFERENCE: Disinfection Feeder. 64E-9.008(10)(e); 64E-9.017(1). A properly sized disinfection feeder and/or generator shall be provided. Electrical pumps must be electrically interlocked with the recirculation pump. Feeders/generators must be certified under NSF/ANSI 50.

Inspection Conducted By: Patrick Nary (936169)  
Inspector Contact Number: Work: (239) 274-2204 ex.  
Print Client Name:  
Date: 5/22/2026

Inspector Signature:

Handwritten signature of Patrick Nary.

Client Signature:

Handwritten signature of the client.